

Discretization of nonlinear continuous systems with time delay: State Space Approach

Bemri H'mida and Soudani Dhaou

Tunis El Manar University
 Laboratory of Research on Automatic (LARA)
 National Engineers School of Tunis BP 37,
 Belvedere 1002 Tunis . Tunisia.

bemrihmid@gmail.com
 dhaou.soudani@enit.rnu.tn

Abstract— Many works are related to the analysis and control of linear system. Although these systems are attractive for several reasons, they also have their limitations. Most real life systems show nonlinear dynamic behavior; a linear model can only describe such a system for a small range of input and output values. In the ever demanding world of today, where systems are pushed to the limits of their performance and accurate descriptions over large input and output ranges are needed, linear models are often not satisfactory anymore. Therefore, a considerable interest for nonlinear systems has risen. As well, the presence of delays makes system analysis and control design much more complicated. Whenever, theory of discrete-time dynamic signals and systems is useful in design and analysis of control systems. For these reason, this paper has been focused on the discretization for the nonlinear systems with time-delay. This discretization scheme is based on Taylor-Lie series. The performance of these proposed discretization methods was validated by doing the numerical simulation using a nonlinear system with state delay. In this simulation initial value, sampling periods and time delay values were adopted.

Keywords — *Discrete-time systems; Time-delay systems; Taylor-Lie series; non-linear systems; Simulation.*

I. INTRODUCTION

Many engineering applications need a compact and accurate description of the dynamic behavior of the system under consideration. This is especially true of automatic control applications. Dynamic models describing the system of interest can be constructed using the first principles of physics, chemistry, biology and so forth.

Time-delay systems often appear in industrial systems and information networks. Thus, it is important to analyze time delay systems and design appropriate controllers. Control systems with time delays exhibit complex behaviors because of their infinite dimensionality. Even in the case of linear time-invariant systems that have constant time delays in their inputs or states have infinite dimensionality if expressed in the continuous time domain. It is therefore difficult to apply the controller design techniques that have been developed during the last several decades for finite-dimensional systems to systems with any time delays in the

variables. Thus, new control system design methods that can solve a system with time delays are necessary.

As a result, controller design techniques developed for finite dimensional systems are difficult to apply to time delay systems with some effectiveness, time delay is often encountered in various engineering systems and its existence is frequently a source of instability. Many of these models are also significantly nonlinear which motivates research in the control of nonlinear systems with time delay. Also, control systems with time delays exhibit complex behavior because of their infinite dimensionality. For this reasons, it's difficult to analyze and design the control algorithm for the nonlinear time delay system in the continuous time domain. It is necessary to develop a method to solve the time delay problem. Most of the proposed approaches deal with linear time-delay control systems and, in particular, with the stability analysis and behavior of such systems with constant and/or uncertain time delays [1,5,8]. Quite recently and on the nonlinear front, nonlinear controllers were systematically synthesized for multivariable nonlinear systems in the presence of sensor and actuator dead time [9,12].

In practice, however, most, if not all, industrial controllers are currently implemented digitally. In the design of model based digital control systems two general approaches can be identified. First, a continuous-time controller is designed based on a continuous-time system model, followed by a digital redesign of the controller in the discrete-time domain to approximate the performance of the original continuous-time controller. Second, a direct digital design approach can be followed based on a discrete time model of the system, where the controller is now directly designed in the discrete-time domain. It is apparent that this alternative approach has the attractive feature of dealing directly with the issue of sampling. It should be emphasized, that in both design approaches time discretization of either the controller or the system model is necessary. Furthermore, note that in controller design for time-delay systems the first approach is troublesome because of the infinite-dimensional nature of the underlying system

dynamics. As a result, the second approach becomes more desirable and will be pursued in the present study.

In particular, the well-known procedure of time discretization of linear time delay systems [10,11,14] is extended to nonlinear input driven systems with constant time delay. All these approaches require a small time step in order to be deemed accurate, and this may not be the case in control applications where large sampling periods are inevitably introduced due to physical and technical limitations [13,15]. Due to the physical and technical limitations, slow sampling has become inevitable. A time discretization method that expands the well-known time discretization of linear time-delay systems [2,3,6,7] to nonlinear continuous-time control systems with time delays [4,17] can solve this problem. The effect of this approach on system theoretic properties of nonlinear systems, such as equilibrium properties, relative order, stability, zero dynamics, and minimum-phase characteristics has also been studied [16,21] and reveals the natural and transparent manner in which Taylor methods permeate the relevant theoretical aspects. A certainly not exhaustive sample of other approaches of notable significance, yet with certain associated practical limitations, are reported in [18], and solid theoretical results on the direct use of discrete time approximations in the control of sampled-data nonlinear systems can be found in [19,20].

In particular, the present study aims at the development of new methods for the time discretization of nonlinear input-driven dynamic systems with time delay based on Taylor series. In particular, the paper is organized as follows: the next section contains some mathematical preliminaries; Section 3 discusses the discretization of system with internal point delay; Section 4 discusses the discretization of system with external point delay; Section 5 discusses the discretization of system with internal and external point delays; Section 6 discusses the linearization of nonlinear state space equation and a numerical example is given in section 7 to illustrate the proposed theoretical results and a concluding remark.

II. PRELIMINARIES

In the present study, single-input nonlinear continuous time control systems with input output time-delays is considered using a state space representation of the form:

$$\dot{x}(t) = f_1(x(t)) + f_2(x(t - \tau_0)) + g_1(x(t))u(t) + g_2(x(t - \tau_0))u(t - \tau_1) \quad (1)$$

where, τ_0 and τ_1 are the time delay and $u(t)$ is the control input.

$$\text{and } \dot{x} = f(x(t - \tau_0), u(t - \tau_1)) \quad (2)$$

where $x \in R^n$ is the vector of the states representing an open and connected set, $u \in R$ is the input variable, m and n are an integer which indicates the order of the input.

τ_0 and τ_1 are the system constant time-delay, that directly affects the input and the state. It is assumed that:

$$f_i : R^n \rightarrow R^n \text{ and } g_i : R^n \rightarrow R^n, i = 1; 2; \dots$$

m and $f : R^n \times R \rightarrow R^n$ are smooth mappings.

An equidistant grid on the time axis with mesh $T = t_{k+1} - t_k > 0$ is considered where sampling interval is $[t_k, t_{k+1}] = [kT, (k+1)T]$ and T is the sampling period. Furthermore, we suppose the time-delay τ_0 and τ_1 mesh T are related as follows

$$\tau_0 = q_0 T, \quad (q_0 \geq 1, \text{ is an integer}) \quad (3)$$

$$\tau_1 = q_1 T, \quad (q_1 \geq 1, \text{ is an integer}) \quad (4)$$

where $q_0, q_1 \in \{0, 1, \dots, m\}$. That is, the time-delay τ_0 and τ_1 are customarily represented as an integer multiple of the sampling period adding a fractional part of T [22].

It is assumed that system (1) is driven by an input that is piecewise constant over the sampling interval, i.e. the zero-order hold (ZOH) assumption holds true:

$$u(t) = u(kT) \equiv u(k) = \text{constant, for } kT < t < (k+1)T \quad (5)$$

III. DISCRETIZATION OF NONLINEAR SYSTEMS WITH INTERNAL POINT DELAY

The nonlinear continuous time control systems with input time delay are considered using a state space representation form:

$$\dot{x}(t) = f_1(x(t)) + g_1(x(t))u(t - \tau_1) \quad (6)$$

based on the zero-order hold assumption and the above notation one can deduce that the delayed input variable attains the following two distinct values within the sampling interval:

$$u(t - \tau_1) = u(kT - q_1 T) \equiv u(k - q_1), \text{ for } kT < t < (k+1)T \quad (7)$$

the nonlinear system (6) can be discretized using Taylor series expansions over the subinterval $kT < t < (k+1)T$ and taking into account (7), one can obtain the state vector evaluated at $(k+1)T$ as a function of $x(k)$ and $u(k - q_1)$.

around the point $x(t_0)$, the state $x(t)$ can be expanded to Taylor series as:

$$x(t) = x(t_0) + x'(t_0)(t - t_0) + \frac{x''(t_0)}{2!}(t - t_0)^2 + \frac{x'''(t_0)}{3!}(t - t_0)^3 + \dots \quad (8)$$

in the time interval $[t_k, t_{k+1}] = [kT, (k+1)T]$, equation (8) can be rewritten using equation (9):

$$x((k+1)T) = x(kT) + x'(kT)T + \frac{x''(kT)}{2!}T^2 + \frac{x'''(kT)}{3!}T^3 + \dots \quad (9)$$

for simplicity and without misunderstanding, equation (9) can be rewritten as:

$$x(k+1) = x(k) + x'(k)T + \frac{x''(k)}{2!}T^2 + \frac{x'''(k)}{3!}T^3 + \dots \quad (10)$$

from equation (6), we can get the differential coefficient of the state $x(t)$:

$$\dot{x}(t) = f_1(x(t)) + g_1(x(t))u(t - \tau_1) \quad (11)$$

then in the time interval $[t_k, t_{k+1}] = [kT, (k+1)T]$, equation (11) can be rewritten using equation (12):

$$\dot{x}(k) = f_1(x(k)) + g_1(x(k))u(k - q_1) \quad (12)$$

similarly, based on equation (6) we can calculate the second derivative of the state $x(t)$, shown in equation (13):

$$\begin{aligned} x''(t) &= \frac{d(x'(t))}{dt} = \frac{d(f_1(x(t)) + g_1(x(t))u(t - \tau_1))}{dt} \\ &= \frac{df_1(x(t))}{dx} \frac{dx}{dt} + u(t - \tau_1) \frac{dg_1(x(t))}{dx} \frac{dx}{dt} + g_1(x(t)) \frac{du(t - \tau_1)}{dt} \quad (13) \\ &= \left(\frac{df_1(x(t))}{dx} + u(t - \tau_1) \frac{dg_1(x(t))}{dx} \right) \frac{dx}{dt} + g_1(x(t)) \frac{du(t - \tau_1)}{dt} \end{aligned}$$

for the zero-order hold assumption, in each sampling interval Equation (13) is correct:

$$\frac{du(t)}{dx} = 0 \Rightarrow \frac{du(t - \tau_1)}{dx} = 0 \quad (14)$$

then in each sampling interval, equation (13) can be expressed using equation (15):

$$\begin{aligned} x''(t) &= \frac{d(x'(t))}{dt} = \left(\frac{df_1(x(t))}{dx} + u(t - \tau_1) \frac{dg_1(x(t))}{dx} \right) \frac{dx}{dt} + g_1(x(t)) \frac{du(t - \tau_1)}{dt} \\ &= \left(\frac{df_1(x(t))}{dx} + u(t - \tau_1) \frac{dg_1(x(t))}{dx} + g_1(x(t)) \frac{du(t - \tau_1)}{dx} \right) \frac{dx}{dt} \quad (15) \\ &= \frac{\partial(f_1(x(t)) + u(t - \tau_1)g_1(x(t)))}{\partial x} \frac{dx}{dt} \end{aligned}$$

or $\frac{dx}{dt} = \dot{x}(t) = f_1(x(t)) + g_1(x(t))u(t - \tau_1)$, then equation (15) can be rewritten as:

$$\begin{aligned} x''(t) &= \frac{d(x'(t))}{dt} = \frac{\partial(f_1(x(t)) + u(t - \tau_1)g_1(x(t)))}{\partial x} \frac{dx}{dt} \quad (16) \\ &= \frac{\partial(f_1(x(t)) + u(t - \tau_1)g_1(x(t)))}{\partial x} (f_1(x(t)) + u(t - \tau_1)g_1(x(t))) \end{aligned}$$

in the time interval $[t_k, t_{k+1}] = [kT, (k+1)T]$, equation (16) can be rewritten using equation (17):

$$x''(k) = \frac{\partial(f_1(x(k)) + u(k - q_1)g_1(x(k)))}{\partial x} (f_1(x(k)) + u(k - q_1)g_1(x(k))) \quad (17)$$

assume that:

$$\begin{aligned} A^{[1]}(x, u) &= f_1(x(k)) + g_1(x(k))u(k - q_1) \\ A^{[2]}(x, u) &= \frac{\partial A^{[1]}(x, u)}{\partial x} f_1(x(k)) + g_1(x(k))u(k - q_1) \quad (18) \\ A^{[l+1]}(x, u) &= \frac{\partial A^{[l]}(x, u)}{\partial x} f_1(x(k)) + g_1(x(k))u(k - q_1) \\ & \quad l = 1, 2, 3, \dots \end{aligned}$$

then equation (17) can be written as:

$$\begin{aligned} x''(k) &= \frac{\partial(f_1(x(k)) + u(k - q_1)g_1(x(k)))}{\partial x} (f_1(x(k)) + u(k - q_1)g_1(x(k))) \\ &= A^{[2]}(x(k), u(k - q_1)) \quad (19) \end{aligned}$$

in the same way, we have:

$$x''' = A^{[3]}(x(k), u(k - q_1)) \quad (20)$$

then equation (10) can be written as:

$$\begin{aligned} x(k+1) &= x(k) + \sum_{l=1}^N \frac{T^l}{l!} \frac{d^l x}{dt^l} \Big|_{t_k} \quad (21) \\ &= x(k) + \sum_{l=1}^N A^{[l]}(x(k), u(k - q_1)) \frac{T^l}{l!} \end{aligned}$$

here $x(k)$ is the value of the state $x(t)$ at the time $t = kT$, $A^{[l]}(x(k), u(k - q_1))$ can be calculated using equation (18).

The Taylor series expansion of equation (21) can offer either an exact sampled data representation of equation (6) by remaining the full infinite series representation of the state vector. It can also provide an approximate sampled data representation of equation (6) resulting from a truncation of the Taylor series order:

$$\begin{aligned} x(k+1) &= \Phi_T^N(x(k), u(k - q_1)) \\ &= x(k) + \sum_{l=1}^N A^{[l]}(x(k), u(k - q_1)) \frac{T^l}{l!} \quad (22) \end{aligned}$$

where, the subscript of Φ denotes the dependence of the sampling period and the superscript N denotes the finite series truncation order of the equation (22).

IV. DISCRETIZATION OF NONLINEAR SYSTEMS WITH EXTERNAL POINT DELAY

The nonlinear continuous time control systems with state delay can be represented by the following state space form:

$$\dot{x}(t) = f(x(t)) + f_1(x(t - \tau_0)) + g(x(t))u(t) + g_1(x(t - \tau_0))u(t) \quad (23)$$

where, τ_0 is the time delay and $u(t)$ is the control input. assume that in the time interval $[t_k, t_{k+1}] = [kT, (k+1)T]$ $\tau_0 = q_0T$, ($q_0 \geq 1$, is an integer)

In the time interval $t \in [kT, (k+1)T]$, $k = 0, 1, \dots, n-1$, $f_1(x(t - \tau_0)) = 0$ and $g_1(x(t - \tau_0))u(t) = 0$. Under the zero-order hold assumption and within the sampling interval, the solution described in equation (23) is expanded in a uniformly convergent Taylor series and the resulting coefficients can be easily computed by taking successive partial derivatives of the right-hand-side of equation (23).

An approximate sampled data representation:

$$x(k+1) = x(k) + \sum_{l=1}^N A^{[l]}(x(k - q_0), u(k)) \frac{T^l}{l!} \quad (24)$$

where, $A^{[l]}(x, u)$ can be calculate using equation (23)

$$\begin{aligned} A^{[1]}(x, u) &= f_1(x(k - q_0)) + g_1(x(k - q_0))u(k) \\ A^{[2]}(x, u) &= \frac{\partial A^{[1]}(x, u)}{\partial x} f_1(x(k - q_0)) + g_1(x(k - q_0))u(k) \\ A^{[l+1]}(x, u) &= \frac{\partial A^{[l]}(x, u)}{\partial x} f_1(x(k - q_0)) + g_1(x(k - q_0))u(k) \\ & \quad l = 1, 2, 3, \dots \end{aligned} \quad (25)$$

in the time interval $t \in [kT, (k+1)T]$, $k = 0, 1, \dots, n-1$, equation (24) provides the approximates sampled data representation of equation (23):

$$x(k+1) = x(k) + \sum_{l=1}^N \left(A^{[l]}(x(k), u(k)) \frac{T^l}{l!} + B^{[l]}(x(k - q_0), u(k)) \frac{T^l}{l!} \right) \quad (26)$$

where, $A^{[l]}(x(k), u(k))$ can be calculated using equation(23), and $B^{[l]}(x(k - q_0), u(k))$ can be calculate using equation (25):

$$\begin{aligned} B^{[1]}(x, u) &= f_1(x(k - q_0)) + g_1(x(k - q_0))u(k) \\ B^{[2]}(x, u) &= \frac{\partial B^{[1]}(x, u)}{\partial x} f_1(x(k - q_0)) + g_1(x(k - q_0))u(k) \\ B^{[l+1]}(x, u) &= \frac{\partial B^{[l]}(x, u)}{\partial x} f_1(x(k - q_0)) + g_1(x(k - q_0))u(k) \\ & \quad l = 1, 2, 3, \dots \end{aligned} \quad (27)$$

The discrete time form of the nonlinear continuous system with state delay, shown in equation (23) can be gotten by combining equation (22) and (24).

V. DISCRETIZATION OF NONLINEAR SYSTEMS WITH INTERNAL AND EXTERNAL POINT DELAYS

The nonlinear continuous time control systems with input output time delays are considered using a state space representation form:

$$\dot{x}(t) = f(x(t)) + f_1(x(t - \tau_0)) + g(x(t))u(t) + g_1(x(t - \tau_0))u(t - \tau_1) \quad (28)$$

where, τ_0 and τ_1 are the time delays and $u(t)$ is the control input.

assume that in the time interval $[t_k, t_{k+1}] = [kT, (k+1)T]$

$$\begin{aligned} \tau_0 &= q_0T, \quad (q_0 \geq 1, \text{ is an integer}) \\ \tau_1 &= q_1T, \quad (q_1 \geq 1, \text{ is an integer}) \end{aligned}$$

based on the zero-order hold assumption and the above notation one can deduce that the delayed input variable attains the following two distinct values within the sampling interval:

$$u(t - \tau_1) = u(kT - q_1T) \equiv u(k - q_1), \text{ for } kT < t < (k+1)T \quad (29)$$

the nonlinear system (26) can be discretized using Taylor series expansions over the subinterval $kT < t < (k+1)T$ and taking into account (27), one can obtain the state vector evaluated at $(k+1)T$ as a function of $x(k - q_0)$ and $u(k - q_1)$.

in the time interval $t \in [kT, (k+1)T]$, $k = 0, 1, \dots, n-1$, equation (24) provides the approximates sampled data representation of equation (23):

$$x(k+1) = x(k) + \sum_{l=1}^N \left(A^{[l]}(x(k), u(k)) \frac{T^l}{l!} + B^{[l]}(x(k - q_0), u(k - q_1)) \frac{T^l}{l!} \right) \quad (30)$$

where, $A^{[l]}(x(k), u(k))$ can be calculated using equation(31), and $B^{[l]}(x(k - q_0), u(k - q_1))$ can be calculate using equation (32):

$$\begin{aligned} A^{[1]}(x, u) &= f_1(x(k)) + g_1(x(k))u(k) \\ A^{[2]}(x, u) &= \frac{\partial A^{[1]}(x, u)}{\partial x} f_1(x(k)) + g_1(x(k))u(k) \\ A^{[l+1]}(x, u) &= \frac{\partial A^{[l]}(x, u)}{\partial x} f_1(x(k)) + g_1(x(k))u(k) \\ & \quad l = 1, 2, 3, \dots \end{aligned} \quad (31)$$

and:

$$\begin{aligned}
B^{[1]}(x,u) &= f_1(x(k-q_0)) + g_1(x(k-q_0))u(k-q_1) \\
B^{[2]}(x,u) &= \frac{\partial B^{[1]}(x,u)}{\partial x} f_1(x(k-q_0)) + g_1(x(k-q_0))u(k-q_1) \\
B^{[l+1]}(x,u) &= \frac{\partial B^{[l]}(x,u)}{\partial x} f_1(x(k-q_0)) + g_1(x(k-q_0))u(k-q_1) \\
& \quad l=1,2,3,\dots
\end{aligned} \tag{32}$$

The discrete time form of the nonlinear continuous system with input output time delays, shown in equation (28) can be gotten by combining equation (22) and (24).

VI. LINEARIZATION OF NONLINEAR STATE SPACE EQUATION

The technique of linearization involves approximating a complicated system of equations with a simpler linear system. We hope to gain insight into the behavior of the nonlinear system through an analysis of the behavior of its linearization. We hope that the nonlinear system will behave locally like its linearization, at least in a qualitative sense.

In general, the linearization of a system of equations about an equilibrium point can be achieved by changing variables so that the equilibrium point is transformed to the origin. Points in the original system close to the equilibrium point will correspond to points close to the origin in the new system. Thus we are only concerned with values of the new variables close to zero and under certain conditions the nonlinear terms can be neglected. The equations that result are linear and are the linearization of the original system.

In order to linearize general nonlinear systems, we will use the Taylor Series expansion of functions.

Consider the nonlinear system:

$$\begin{cases} \dot{x} = f(x,u) \\ y = g(x,u) \end{cases} \tag{33}$$

with the equilibrium point is (p,q) . Any function which is differentiable can be written as a Taylor series expansion for $f(x,u)$ with neglect the terms of high order:

$$\dot{x} = f(x,u) = f(p,q) + \frac{\partial f}{\partial x} \Big|_{(p,q)} (x-p) + \frac{\partial f}{\partial u} \Big|_{(p,q)} (u-q) + F(x,u) \tag{34}$$

where $F(x,u)$ consists of nonlinear polynomial terms in $(x-p)$ and $(u-q)$.

since (p,q) is an equilibrium $f(p,q) = 0$ and neglect high order terms, then the state space representation form (33) can be rewritten as:

$$\dot{x} = f(x,u) = \frac{\partial f}{\partial x} \Big|_{(p,q)} (x-p) + \frac{\partial f}{\partial u} \Big|_{(p,q)} (u-q) + F(x,u) \tag{35}$$

for points near to the equilibrium point $(x-p)$ and $(u-q)$ are small and the nonlinear terms $F(p,q)$ can be neglected.

We can write the state space model as:

$$\dot{x} = f(x,u) = \frac{\partial f}{\partial x} \Big|_{(p,q)} (x-p) + \frac{\partial f}{\partial u} \Big|_{(p,q)} (u-q) \tag{36}$$

where the elements of linearization matrices are:

$$A_{ij} = \frac{\partial f_i}{\partial x_j} \Big|_{(p,q)} = \begin{pmatrix} \frac{\partial f_1}{\partial x_1} \Big|_{(p,q)} & \frac{\partial f_1}{\partial x_2} \Big|_{(p,q)} \\ \frac{\partial f_2}{\partial x_1} \Big|_{(p,q)} & \frac{\partial f_2}{\partial x_2} \Big|_{(p,q)} \end{pmatrix}, B_{ij} = \frac{\partial f_i}{\partial u_j} \Big|_{(p,q)} = \begin{pmatrix} \frac{\partial f_1}{\partial u} \Big|_{(p,q)} \\ \frac{\partial f_2}{\partial u} \Big|_{(p,q)} \end{pmatrix}$$

$$C_{ij} = \frac{\partial g_i}{\partial x_j} \Big|_{(p,q)} \quad \text{and} \quad D_{ij} = \frac{\partial g_i}{\partial u_j} \Big|_{(p,q)}$$

where A_{ij} is called the Jacobian matrix.

VII. RESULT OF SIMULATIONS

The performance of the proposed methods of discretization for nonlinear systems with time delays is evaluated by applying it to a nonlinear continuous system with time delays. The partial derivative terms involved in the Taylor series expansion are determined recursively. The system considered in this paper is assumed to be a nonlinear control system, as it considers the pendulum equation with friction:

$$f(x,u) = \begin{cases} \dot{x}_1 = x_2 \\ \dot{x}_2 = -\frac{g}{l} \sin x_1 - \frac{k}{m} x_2 + u(t-\tau) \end{cases} \tag{37}$$

The vector $u(t)$, called the input history or control input, is chosen to influence the dynamics in some desired way. The vector of functions f describes the system's dynamics and the vector of functions h provides a set of output measurements. We call any pair $(x(t), u(t))$ satisfying over some time interval including $(t = t_0)$ a solution or trajectory.

Note that any system of higher order differential equations can be written in the first-order form. For example, the motion of a simple pendulum with an input torque is described by the second order nonlinear equation:

$$T = 0.2s, \quad \tau = 0.2s, \quad \frac{g}{l} = 1 \quad \text{and} \quad \frac{k}{m} = 0.5$$

$$f(x,u) = \begin{pmatrix} x_2 \\ -\sin x_1 - 0.5x_2 + u(t-0.2) \end{pmatrix} \quad (38)$$

$$= \begin{pmatrix} 0 & 1 \\ -\sin x_1 & -0.5 \end{pmatrix} \begin{pmatrix} x_1 \\ x_2 \end{pmatrix} + \begin{pmatrix} 0 \\ 1 \end{pmatrix} u(t-0.2)$$

with:

$$x = \begin{pmatrix} x_1 \\ x_2 \end{pmatrix} \quad A = \begin{pmatrix} 0 & 1 \\ -\sin x_1 & -0.5 \end{pmatrix} \quad B = \begin{pmatrix} 0 \\ 1 \end{pmatrix}$$

the Jacobian matrix of the function $f(x,u)$ of the pendulum equation is given by:

$$\frac{\partial f}{\partial x} = \begin{pmatrix} \frac{\partial f_1}{\partial x_1} & \frac{\partial f_1}{\partial x_2} \\ \frac{\partial f_2}{\partial x_1} & \frac{\partial f_2}{\partial x_2} \end{pmatrix} = \begin{pmatrix} 0 & 1 \\ -\cos(x_1) & -0.5 \end{pmatrix} \quad (39)$$

$$\frac{\partial f}{\partial u} = \begin{pmatrix} \frac{\partial f_1}{\partial u} \\ \frac{\partial f_2}{\partial u} \end{pmatrix} = \begin{pmatrix} 0 \\ 1 \end{pmatrix} \quad (40)$$

evaluating the Jacobian matrix at the equilibrium points $(0, 0)$ and $(\pi, 0)$ yields, respectively, the two matrices

$$A_1 = \begin{pmatrix} 0 & 1 \\ 1 & -0.5 \end{pmatrix} \text{ and } A_2 = \begin{pmatrix} 0 & 1 \\ -1 & -0.5 \end{pmatrix}$$

The Taylor series expansion of equation (21) can offer either an exact sampled data representation of the equation (6) by remaining the full infinite series representation of the state vector. it can also provide an approximate sampled data representation of equation (6) resulting from a truncation of the Taylor series order:

$$x(k+1) = x(k) + A_i(x(k), u(k-1))T \quad (41)$$

the simulation results is depicted in the figure 1




Figure 1. Step response of nonlinear continuous and discrete system with control time delay

In the second case, the nonlinear continuous time control systems with state delay can be represented by the following state space form:

$$x(k+1) = x(k) + A_i(x(k-1), u(k))T \quad (42)$$

the simulation results is depicted in the figure 2




Figure 2. Step response of nonlinear continuous and discrete system with state time delay

In the third case, the nonlinear continuous time control systems with input output time delays are considered using a state space representation form:

$$x(k+1) = x(k) + (A(x(k), u(k))T + A_i(x(k-q_0), u(k-q_1))T) \quad (43)$$

the simulation results is depicted in the figure 3




Figure 3. Step response of nonlinear continuous and discrete system with input output time delay

Eventually, the simulation using a nonlinear system with time delay is conducted to validate the proposed time discretization method.

VIII. CONCLUSION

This paper proposed a time discretization method for nonlinear continuous systems with internal and external point delay. This proposed discretization method is based on Taylor series. The performance of the proposed time discretization method is evaluated using a nonlinear system with time delayed. The derived time discretization method provides a finite dimensional representation for nonlinear

control systems with time delay, thereby enabling the application of existing nonlinear controller design techniques to such systems.

Finally, the simulation results show that the proposed discretization method does not change the original system stability nor increase much computational burden.

REFERENCES

- [1] Z. Kowalczuk.: Discrete approximation of continuous-time systems. *A survey, proc. Iee-g,144*, pp. 264–278, 1993.
- [2] A. El moudni,ben sassi b.: On a new order reduction method for discrete systems. *12th world congress on scientific computation imacs,pp.95-99,1988*.
- [3] J. Jugo.: Discretization of continuous time delay stems. *15th triennial word congress, d. Electricidad y electronica, f. De ciencias,upv/ehu,apdo.644,bilbao,barcelona, spain ifac, 2002*.
- [4] N.k sinha and zou q. :Discrete time approximation of multivariable continuous time systems. *Iee proceedings, vol 130,pt.d,n°3 ,pp 103-110,1983*.
- [5] Z. Qing-chang: Robust control of time-delay systems. *Ieee transactions on automatic control ,53*, pp. 636-637, 2008.
- [6] B.H'mida,M.Sahbi and S.Dhaou: Discrete-time approximation of multivariable continuous-time delay systems. *IGI global handbook of research on advanced intelligent control engineering and automation, pp516-542, doi: 10.4018/978-1-4666-7248-2.ch019, January 2015*.
- [7] B.H'mida,M.Sahbi and S.Dhaou: Discretizing of linear systems with time-delay using method of euler's and tustin's approximations. *International journal of engineering research and applications (ijera) , issn: 2248-9622 , vol. 5 -issue 3, march 2015*.
- [8] S.Magdi Mahmoud.:Robust filtering for time-delay systems. *Marcel dekker,elsevier science inc. New york, ny, usa.an international journal,vol 176,issue 2,pp.186-200,2000*.
- [9] N.k., Sinha and Lastman, G.J.: Transformation algorithm for identification of continuous-time multivariable systems from discrete data. *Electron. Lett, 17*, pp. 779-780,1981.
- [10] L.s. Shieh, Yeung, C.k., and McInnis, B.C.: Solutions of state-space equations via block-pulse functions. *Int. J. Control, 28*, pp. 383-392,1978.
- [11] W. Michiels, v. Van assche, and s.-i. Niculescu: stabilization of time-delay. *Ieee transactions on automatic control, vol. 50, no. 4, april 2005*.
- [12] E. Fridman, U. Shaked, and V. Suplin., :Input/output delay approach to robust sampled-data h_{∞} control. *Systems & control letters, vol. 54, no. 3, pp. 271 - 282, 2005*.
- [13] W. Michiels and S.-I. Niculescu . : Stability and stabilization of time-delay systems. *An eigenvalue-based approach, ser. Advances in design and control. Vol. 12., siam, 2007*.
- [14] B. H'mida, M. Sahbi and S. Dhaou: Stability of a linear discrete system with time delay via lyapunov-krasovskii functional. *International journal of scientific research & engineering technology (ijset). Issn: 2356-5608, vol.3, issue 3, copyright ipco,pp .62-66, 2015*.
- [15] M. Vidyasagar, Nonlinear Systems Analysis. *Prentice Hall, Englewood Cliffs, NJ, USA.1978*.
- [16] Zidong Wang, James lam, senior and Xiaohui Liu: Nonlinear filtering for state delayed systems with markovian switching. *Ieee transactions on signal processing, vol. 51, no. 9, september 2003*.
- [17] Yuanliang Zong : A discretization method for the nonlinear state delay system. *Information technology journal, 13(6), pp.1222-1227, 2014*.
- [18] Yuan-Liang Zhang: Discretization of nonlinear non-affine time delay systems based on second-order hold. *International journal of automation and computing, 11(3),pp 320-327 june 2014*.
- [19] Yuanliang Zhang and Kil To Chong: Time-discretization of time delayed non-affine system via Taylor-lie series using scaling and squaring technique. *International journal of control, automation, and systems, vol. 4, no. 3, pp. 293-301, june 2006*.
- [20] Zheng Zhang and Kil To Chong: second order hold and Taylor series based discretization of siso input time-delay systems. *Journal of mechanical science and technology 23 pp136-148, 2009*.
- [21] Y. L. Zhang: Discretization of nonlinear non-affine time delay system using first order hold assumption with scaling and squaring technique. *International Review on Computers and Software, vol. 7, no. 4, pp. 1860-1865, 2012*.
- [22] Y. L. Zhang, O. Kostyukova, K. T. Chong: A new time discretization for delay multiple-input nonlinear systems using the Taylor method and first order hold. *Discrete Applied Mathematics, vol. 159, no. 9, pp. 924-938, 2011*.

AUTHORS' INFORMATION



Bemri H'mida was born in Tunisia. He received the scientific degree in mathematics, physics and computer science within the Faculty of Sciences of Tunis (FST) in 2003. He received the degree of MA within the Faculty of Sciences of Tunis (FST) in 2005. He received the certificate of Aptitude Teaching of Second Degree (CAPES) in 2008. He has been working as a teacher in 2 Mars1934 secondary school in Siliana since 2008. He received the degree of Master of Research in automatic and signals processing (ATS) within the National Engineering School of Tunis (ENIT) in 2013. His research interests include modeling and control systems sampled to delays.



Dhaou Soudani was born in Tunisia. He received the Master degree in Electrical and Electronic Engineering and the "Diplôme des Etudes Approfondies" in Automatic Control from the "Ecole Normale Supérieure de l'Enseignement Technique" Tunisia in 1982 and 1984, respectively. He obtained both the Doctorat in 1997, and the "Habilitation Universitaire" in 2007 in Electrical Engineering from the "Ecole Nationale d'Ingénieurs de Tunis" (ENIT) Tunisia. He is currently a professor in Automatic Control and a member of the unit research "Laboratoire de Recherche en Automatique" (L.A.R.A).